

**ANNO 2018 - Impianto depurazione di BORGOLAVEZZARO - Campione medio composito sulle 24 ore Limite di legge Tab. 1 All. 5 DLgs 152/06**

	<b>BOD5</b>		<b>COD</b>		<b>SS</b>	
	mg/l - in ingresso	mg/l - allo scarico	mg/l - in ingresso	mg/l - allo scarico	mg/l - in ingresso	mg/l allo scarico
<b>Data/Limite (152/2006)</b>		<b>25</b>		<b>125</b>		<b>35</b>
<b>24/01/2018</b>	48,0	5,0	187,0	19,0	65,0	3,0
<b>28/03/2018</b>	36,0	5,0	174,0	26,0	39,0	3,0
<b>22/05/2018</b>	5,0	5,0	22,0	12,6	8,0	2,0
<b>21/08/2018</b>	10,0	7,0	49,0	38,0	11,0	10,0
<b>01/10/2018</b>	95,0	5,0	261,0	15,4	220,0	4,0
<b>03/12/2018</b>	32,0	5,0	79,0	5,0	40,0	4,0
media	38	5	129	19	64	4